



Colorado Department
of Public Health
and Environment

Total Trihalomethane Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revision: 4/13/2015

TTHM

Section I (to be completed by the Public Water Systems only)					Section II (to be completed by Laboratories only)					
Public Water System Information					Laboratory Information					
PWSID#: CO0115685			Facility ID:DS001		Laboratory ID: CO015					
System Name: Rogers Mesa Domestic Water					Laboratory Name: Colorado Analytical Laboratory					
Contact Person: James Firor			Phone #:		Contact Person: Customer Service			Phone: 303-659-2313		
Comments:					Comments:					
Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
4/18/23	DBP001	SM2 J Road	4/19/23	4/20/23	230419032-01A	Chloroform	EPA-524.2	N/A	0.5	51.28
						Bromoform	EPA-524.2	N/A	0.5	0.94
						Bromodichloromethane	EPA-524.2	N/A	0.5	33.24
						Dibromochloromethane	EPA-524.2	N/A	0.5	15.30
						Total Trihalomethanes	EPA-524.2	80	0.5	100.8

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter
MCL: Maximum Contaminant Level

4/28/23
230419032
1/1
Y

Drinking Water Chain of Custody



Report To Information		Bill To Information (If different from report to)		Project Information	
Company Name: <u>Rogers Mesa Domestic</u>		Company Name: <u>Rogers Mesa Domestic Water Co</u>		PWSID: <u>C00115685</u>	
Contact Name: <u>James Firor</u>		Contact Name: <u>Diane Perry</u>		System Name: <u>Rogers Mesa Domestic Water</u>	
Address: <u>PO Box 428</u>		Address: <u>PO Box 428</u>		Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
City: <u>Hatch</u> State: <u>CO</u> Zip: <u>81419</u>		City: <u>Hatch</u> State: <u>CO</u> Zip: <u>81419</u>		Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Phone: <u>970 424-2409</u>		Phone: <u>970 424-2250</u>		Task Number (Lab Use Only) CAL Task 230419032 JAK	
Email: <u>badrabit@tds.net</u>		Email: <u>rogersmesadomesticwater@gmail.com</u>			
Sample Collector: <u>JF</u>					
Sample Collector Phone: <u>970 424-2409</u>		PO Number:			

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
610 Garrison Street, Unit E
Lakewood CO 80215

Phone: 303-659-2313

www.coloradolab.com

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																	Subcontract Analyses										
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
4/18/23	1:45	DW007 / W. L Rd DW001 / W. L Rd																												
		CSM2 J Road - per MON. Schedule) 4																												

Instructions:				C/S Info:				Seals Present Yes <input type="checkbox"/> No <input type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input type="checkbox"/>							
Relinquished By: <u>J. Firor</u>		Date/Time: <u>4/18 2:25</u>		Received By: <u>WA</u>		Date/Time: <u>4-19-23</u>		Delivered Via: <u>UPS</u>		C/S Charge: <input checked="" type="checkbox"/>		Temp. <u>9</u> °C / Ice <u>7</u>		Sample Pres. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	