

Lead and Copper Sampled in the Distribution System								
Contaminant Name	Time Period*	90 <sup>th</sup> Percentile	Sample Size	Unit of Measure	90 <sup>th</sup> Percentile AL	Sample Sites Above AL	90 <sup>th</sup> Percentile AL Exceedance	Typical Sources
Copper	08/28/2021 to 08/28/2021*	0.61	10	ppm	1.3	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	08/28/2021 to 08/28/2021*	2	10	ppb	15	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

\*Lead and copper sampling is required only every three years for our system