



Colorado Department
of Public Health
and Environment

Haloacetic Acids Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revision: 4/13/2015

HAA5

Section I (to be completed by the Public Water Systems only)					Section II (to be completed by Laboratories only)					
Public Water System Information					Laboratory Information					
PWSID#: CO0115685			Facility ID:DS001		Laboratory ID: CO015					
System Name: Rogers Mesa Domestic Water					Laboratory Name: Colorado Analytical Laboratory					
Contact Person: James Firor			Phone #:		Contact Person: Customer Service			Phone: 303-659-2313		
Comments:					Comments:					
Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
1/16/24	DBP001	SM2 JRoad	1/17/24	1/20/24	240117065-01	Monochloroacetic Acid	EPA 552.2	N/A	2.0	BDL
						Monobromoacetic Acid	EPA 552.2	N/A	1.0	BDL
						Dichloroacetic Acid	EPA 552.2	N/A	1.0	13.96
						Trichloroacetic Acid	EPA 552.2	N/A	1.0	12.28
						Dibromoacetic Acid	EPA 552.2	N/A	1.0	BDL
Total Haloacetic Acids	EPA 552.2	60	1.0	26.2						

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter
MCL: Maximum Contaminant Level

1/31/24
240117065
1/1
Y

Drinking Water Chain of Custody



Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
610 Garrison Street, Unit E
Lakewood CO 80215

Phone: 303-659-2313

www.coloradolab.com

Report To Information	Bill To Information (If different from report to)	Project Information
Company Name: <u>Rogers Mesa Water</u>	Company Name: _____	PWSID: <u>C00115685</u>
Contact Name: <u>James Firov</u>	Contact Name: <u>Diane Perry</u>	System Name: <u>Rogers Mesa Domestic Water</u>
Address: <u>PO Box 428</u>	Address: <u>PO Box 428</u>	Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
City: <u>Hatch</u> State: <u>CO</u> Zip: <u>81419</u>	City: <u>Hatch</u> State: <u>CO</u> Zip: <u>81419</u>	Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Phone: <u>970 424-2409</u>	Phone: <u>970 424-2250</u>	Task Number (Lab Use Only): CAL Task 240117065
Email: <u>badrabit@tds.net</u>	Email: <u>rogersmesadomesticwater@gmail.com</u>	SLM
Sample Collector: <u>James Firov</u>	PO Number: _____	
Sample Collector Phone: <u>970 424-2409</u>		

PHASE I, II, V Drinking Water Analyses (check requested analysis)

Subcontract Analyses

Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbarnates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk/Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
																														✓
<u>1/16/24</u>		<u>DBP001/B&Q</u>																												
		4																												

Per James, time collected was 12:50pm 1/18/24 SLM

Instructions: <u>* Sample ID per monitoring schedule 1/17/24 slm</u>	C/S Info: _____	Seals Present Yes <input type="checkbox"/> No <input type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input type="checkbox"/>
Relinquished By: <u>Firov</u>	Date/Time: <u>1/16/23/12:50</u>	Received By: <u>KA</u>
Relinquished By: _____	Date/Time: <u>1/17/24</u>	Received By: _____

Delivered Via: USPS C/S Charge: Temp: 7 °C/ice Sample Pres. Yes No